



THE ASSAM GAZETTE

অসাধাৰণ

EXTRAORDINARY

প্ৰাপ্ত কৰ্তৃত্বৰ দ্বাৰা প্ৰকাশিত

PUBLISHED BY THE AUTHORITY

নং ৪ দিশপুৰ, বুধবাৰ, ৭ জানুৱাৰী, ২০১৫, ১৭ পূহ, ১৯৩৬ (শক)
No. 8 Dispur, Wednesday, 7th January, 2015, 17th Pausa, 1936 (S.E.)

GOVERNMENT OF ASSAM
ORDERS BY THE GOVERNOR
ASSAM ELECTRICITY REGULATORY COMMISSION

NOTIFICATION

Dated Guwahati the 6th January, 2015

ASSAM ELECTRICITY REGULATORY COMMISSION (TERMS AND CONDITIONS FOR DETERMINATION OF TARIFF) (FIRST AMENDMENT) REGULATIONS, 2014

No. AERC.441/2014/29 In exercise of the powers conferred on it by Section 61 read with Section 181(zd) of the Electricity Act, 2003 (36 of 2003) and all powers enabling in that behalf, and after previous publication, the Assam Electricity Regulatory Commission makes the following regulations to amend the AERC (Terms and conditions for determination of tariff) regulations, 2006 (hereinafter referred to as “the Principal Regulations”), namely:-

REGULATIONS

1. SHORT TITLE AND COMMENCEMENT:

- 1.1. These regulations shall be called the “Assam Electricity Regulatory Commission (Terms and conditions for determination of tariff) (first amendment) Regulations, 2014
- 1.2. These regulations shall extend to the whole of the State of Assam.
- 1.3. These regulations shall come into force from the date of their publication in the official Gazette of Govt. of Assam.

2. AMENDMENT OF ANNEXURE II OF THE PRINCIPAL REGULATIONS:

The annexure-II of the principal regulations shall be substituted as under:

Station	Approved (Previous) GSHR (Kcal/kWh)	Amended GSHR (Kcal/kWh)
NTPS (Open Cycle)	-	4300
NTPS (Closed Cycle)	3266	3900
LTPS(Open Cycle)	3658	3900
LTPS (Closed Cycle)	-	3200
For new gas turbine – Open cycle	2830	2830
For new gas turbine – Combined cycle	1950	1950

3. AMENDMENT OF ANNEXURE III OF THE PRINCIPAL REGULATIONS:

The annexure-III of the principal regulations shall be substituted as under:

Station	Approved Auxiliary Consumption Rate (%)	Amended Auxiliary Consumption Rate (%)
NTPS (Open Cycle)	-	2.5
NTPS (Close Cycle)	4.5	4.5
LTPS (Open Cycle)	5.5	4.0
LTPS (Close Cycle)	-	5.5
For new gas turbine – open cycle (without gas booster compressor)	1.0	1.0
For new gas turbine – open cycle (with gas booster compressor)	-	4.0
For new gas turbine – combined cycle (without gas booster compressor)	3.0	3.0
For new gas turbine – combined cycle (with gas booster compressor)	-	5.5

(By order of the Commission)

S.K. ROY,
Secretary
Assam Electricity Regulatory Commission